


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Prof. Dr.rer.nat. Lothar Dunemann

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:
Rotthauer Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0
Telefax +49 (0)209 9242-222
Internet www.hyg.de

Our reference: W-336769e-20-Zd
Contact person: Dipl.-Ing. (FH) S. Horn

Gelsenkirchen, 25.11.2020

Test - certificate

hygiene-conformity check to the design requirements of
selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
45879 Gelsenkirchen

Test object: CU2

Manufacturer: RF-Technologies
Lange Ambachstraat 40
9860 Oosterzele - Begium



Basis of the examination: ✓ VDI 6022, sheet 1 (01/2018) ✓ DIN EN 16798, sheet 3 (11/2017)
✓ DIN 1946, part 4 (09/2018) ✓ VDI 3803, sheet 1 (05/2020)
✓ ÖNORM H 6020 (06/2019) ✓ ÖNORM H 6021 (08/2016)
✓ SWKI VA104-01 (01/2019) ✓ SWKI VA105-01 (08/2015)

Validity period: 5 years 11/2020 – 11/2025

Test report: W-336769-20-Zd

In conclusion it can be stated that the examined CU2, as specified in the test report W-336769-20-Zd, is in compliance with the above mentioned regulations.

(Dipl.-Ing. (FH) S. Horn)
Head of the Department hygienic building technology

(B. Zeidler)
clerk of the Department hygienic building technology

issued 25.11.2020, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Register: VR 519 Local Court Gelsenkirchen (Germany); VAT ID: DE125018356
Directorate: Prof. Dr. Jürgen Kretschmann (Head), Dr. Emanuel Grün, Dr. Dirk Waider, Joachim Löchte, Prof. Dr. Lothar Dunemann (Executive Member).